

The Fukushima Daiichi Incident

- 1. Plant Design
- 2. Accident Progression
- 3. Radiological releases
- 4. Spent fuel pools
- 5. Sources of Information

Matthias Braun PEPA4-G, AREVA–NP GmbH Matthias.Braun@AREVA.com



Fukushima Daiichi (Plant I)

- Unit I GE Mark I BWR (439 MW), Operating since 1971
- Unit II-IV GE Mark I BWR (760 MW), Operating since 1974



Building structure

- Concrete Building
- Steel-framed Service Floor



Containment Pear-shaped Dry-Well Torus-shaped Wet-Well







The Fukushima Daiichi Incident – Dr. Matthias Braun - 2 April 2011 - p.5

Lifting the Containment closure head







The Fukushima Daiichi Incident – Dr. Matthias Braun - 2 April 2011 - p.6



11.3.2011 14:46 - Earthquake

- 🔶 Magnitude 9
- Power grid in northern Japan fails
- Reactors itself are mainly undamaged

SCRAM

- Power generation due to Fission of Uranium stops
- Heat generation due to radioactive Decay of Fission Products
 - After Scram ~6%
 - After 1 Day ~1%
 - After 5 Days ~0.5%



Containment Isolation

- Closing of all non-safety related
 Penetrations of the containment
- Cuts off Machine hall
- If containment isolation succeeds, a large early release of fission products is highly unlikely
- Diesel generators start
 - Emergency Core cooling systems are supplied
- Plant is in a stable save state





11.3. 15:41 Tsunami hits the plant

- Plant Design for Tsunami height of up to 6.5m
- Actual Tsunami height >7m
- Flooding of
 - Diesel Generators and/or
 - Essential service water building cooling the generators
- Station Blackout
 - Common cause failure of the power supply
 - Only Batteries are still available
 - Failure of all but one Emergency core cooling systems





Reactor Core Isolation Pump still available

- Steam from the Reactor drives a Turbine
- Steam gets condensed in the Wet-Well
- Turbine drives a Pump
- Water from the Wet-Well gets pumped in Reactor
- Necessary:
 - Battery power
 - Temperature in the wet-well must be below 100°C
- As there is no heat removal from the building, the Core isolation pump cant work infinitely





Reactor Isolation pump stops

- 11.3. 16:36 in Unit 1 (Batteries empty)
- 14.3. 13:25 in Unit 2 (Pump failure)
- 13.3. 2:44 in Unit 3 (Batteries empty)
- Decay Heat produces still steam in Reactor pressure Vessel
 - Pressure rising
- Opening the steam relieve valves
 Discharge Steam into the Wet-Well
- Descending of the Liquid Level in the Reactor pressure vessel



Reactor Isolation pump stops

- 11.3. 16:36 in Unit 1 (Batteries empty)
- 14.3. 13:25 in Unit 2 (Pump failure)
- 13.3. 2:44 in Unit 3 (Batteries empty)
- Decay Heat produces still steam in Reactor pressure Vessel
 - Pressure rising
- Opening the steam relieve valves
 Discharge Steam into the Wet-Well
- Descending of the Liquid Level in the Reactor pressure vessel





Reactor Isolation pump stops

- 11.3. 16:36 in Unit 1 (Batteries empty)
- 14.3. 13:25 in Unit 2 (Pump failure)
- 13.3. 2:44 in Unit 3 (Batteries empty)
- Decay Heat produces still steam in Reactor pressure Vessel
 - Pressure rising
- Opening the steam relieve valves
 Discharge Steam into the Wet-Well
- Descending of the Liquid Level in the Reactor pressure vessel



AREVA



Reactor Isolation pump stops

- 11.3. 16:36 in Unit 1 (Batteries empty)
- 14.3. 13:25 in Unit 2 (Pump failure)
- 13.3. 2:44 in Unit 3 (Batteries empty)
- Decay Heat produces still steam in Reactor pressure Vessel
 - Pressure rising
- Opening the steam relieve valves
 Discharge Steam into the Wet-Well
- Descending of the Liquid Level in the Reactor pressure vessel





Reactor Isolation pump stops

- 11.3. 16:36 in Unit 1 (Batteries empty)
- 14.3. 13:25 in Unit 2 (Pump failure)
- 13.3. 2:44 in Unit 3 (Batteries empty)
- Decay Heat produces still steam in Reactor pressure Vessel
 - Pressure rising
- Opening the steam relieve valves
 Discharge Steam into the Wet-Well
- Descending of the Liquid Level in the Reactor pressure vessel





- Measured, and here referenced Liquid level is the collapsed level. The actual liquid level lies higher due to the steam bubbles in the liquid
- ~50% of the core exposed
 - Cladding temperatures rise, but still no significant core damage
- ~2/3 of the core exposed
 - Cladding temperature exceeds ~900°C
 - Balooning / Breaking of the cladding
 - Release of fission products form the fuel rod gaps



~3/4 of the core exposed

- Cladding exceeds ~1200°C
- Zirconium in the cladding starts to burn under Steam atmosphere
- Zr + 2H₂0 ->ZrO₂ + 2H₂
- Exothermal reaction further heats the core
- Generation of hydrogen
 - Unit 1: 300-600kg
 - Unit 2/3: 300-1000kg
- Hydrogen gets pushed via the wet-well, the wet-well vacuum breakers into the dry-well



at ~1800°C

[Unit 1,2,3]

- Melting of the Cladding
- Melting of the steel structures
- ▶ at ~2500°C [Block 1,2]
 - Breaking of the fuel rods
 - debris bed inside the core
- ▶ at ~2700°C

[Block 1]

- Melting of Uranium-Zirconium eutectics
- Restoration of the water supply stops accident in all 3 Units
 - Unit 1: 12.3. 20:20 (27h w.o. water)
 - Unit 2: 14.3. 20:33 (7h w.o. water)
 - Unit 3: 13.3. 9:38 (7h w.o. water)



- Release of fission products during melt down
 - Xenon, Cesium, Iodine,...
 - Uranium/Plutonium remain in core
 - Fission products condensate to airborne Aerosols
- Discharge through valves into water of the condensation chamber
 - Pool scrubbing binds a fraction of Aerosols in the water
- Xenon and remaining aerosols enter the Dry-Well
 - Deposition of aerosols on surfaces further decontaminates air





Containment

- Last barrier between Fission Products and Environment
- Wall thickness ~3cm
 - Design Pressure 4-5bar
- Actual pressure up to 8 bars
 - Normal inert gas filling (Nitrogen)
 - Hydrogen from core oxidation
 - Boiling condensation chamber (like a pressure cooker)
- Depressurization of the containment
 - + Unit 1: 12.3. 4:00
 - 🔶 Unit 2: 13.3 00:00
 - 🔶 Unit 3: 13.3. 8.41





- Positive und negative Aspects of depressurizing the containment
 - Removes Energy from the Reactor building (only way left)
 - Reducing the pressure to ~4 bar
 - Release of small amounts of Aerosols (Iodine, Cesium ~0.1%)
 - Release of all noble gases
 - Release of Hydrogen
- Gas is released into the reactor service floor
 - Hydrogen is flammable



Unit 1 und 3

- Hydrogen burn inside the reactor service floor
- Destruction of the steel-frame roof
- Reinforced concrete reactor building seems undamaged
- Spectacular but minor safety relevant

Unit 2

- Hydrogen burn inside the reactor building
- Probably damage to the condensation chamber (highly contaminated water)
- Uncontrolled release of gas from the containment

Release of fission products

- Temporal evacuation of the plant
- High local dose rates on the plant site due to wreckage hinder further recovery work

No clear information's why Unit 2 behaved differently

Current status of the Reactors

- Core Damage in Unit 1,2, 3
- Building damage due to various burns Unit 1-4
- Reactor pressure vessels floode in all Units with mobile pumps
- At least containment in Unit 1 flooded
- Further cooling of the Reactors by releasing steam to the atmospher
- Only small further releases of fission products can be expected

Directly on the plant site

- Before Explosion in Unit Block 2
 - Below 2mSv / h
 - Mainly due to released radioactive noble gases
 - Measuring posts on west side. Maybe too small values measured due to wind
- After Explosion in Unit 2 (Damage of the Containment)
 - Temporal peak values 12mSv / h
 - (Origin not entirely clear)
 - Local peak values on site up to 400mSv /h (wreckage / fragments?)
 - Currently stable dose on site at 5mSv /h
 - Inside the buildings a lot more
- Limiting time of exposure of the workers necessary

Zeitpunkt der Messung (Ortszeit japanische Anlage)

Outside the Plant site

- As reactor building mostly intact
 reduced release of Aerosols (not Chernobyl-like)
- Fission product release in steam
 => fast Aerosol grows, large fraction falls down in the proximity of the plant
- Main contribution to the radioactive dose outside plant are the radioactive noble gases
- Carried / distributed by the wind, decreasing dose with time
- No "Fall-out" of the noble gases, so no local high contamination of soil

~20km around the plant

- Evacuations were adequate
- Measured dose up to 0.3mSv/h for short times
- Maybe destruction of crops / dairy products this year
- Probably no permanent evacuation of land necessary

The Fukushima Daiichi Incident 4. Spend fuel pools

Spend fuel stored in Pool on Reactor service floor

- Due to maintenance in Unit 4 entire core stored in Fuel pool
- Dry-out of the pools
 - Unit 4: in 10 days
 - Unit 1-3,5,6 in few weeks
- Leakage of the pools due to Earthquake?

Consequences

- Core melt "on fresh air "
- Nearly no retention of fission products
- + Large release

The Fukushima Daiichi Incident 4. Spend fuel pools

Spend fuel stored in Pool on Reactor service floor

- Due to maintenance in Unit 4 entire core stored in Fuel pool
- Dry-out of the pools
 - Unit 4: in 10 days
 - Unit 1-3,5,6 in few weeks
- Leakage of the pools due to Earthquake?

Consequences

- Core melt "on fresh air "
- Nearly no retention of fission products
- + Large release

The Fukushima Daiichi Incident 4. Spend fuel pools

Spend fuel stored in Pool on Reactor service floor

- Due to maintenance in Unit 4 entire core stored in Fuel pool
- Dry-out of the pools
 - Unit 4: in 10 days
 - Unit 1-3,5,6 in few weeks
- Leakage of the pools due to Earthquake?

Consequences

- Core melt "on fresh air "
- Nearly no retention of fission products
- Large release

It is currently unclear if release from fuel pool already happened

The Fukushima Daiichi Incident 5. Sources of Information

Good sources of Information

- Gesellschaft f
 ür Reaktorsicherheit [GRS.de]
 - Up to date
 - Radiological measurements published
 - German translation of japanese/englisch web pages
- Japan Atomic Industrial Forum [jaif.or.jp/english/]
 - Current Status of the plants
 - Measurement values of the reactors (pressure liquid level)
- Tokyo Electric Power Company [Tepco.co.jp]
 - Status of the recovery work
 - Casualties

May too few information are released by TEPCO, the operator of the plant

NEWS UPDATES

April 12, 2011

The Japanese government's nuclear safety agency raises the crisis level of the Fukushima Daiichi power plant accident from 5 to 7, the worst on the international scale matching that of the 1986 USSR Chernobyl accident. (See the attached reactor status report that follows)

Unit	1	2	3	4
Power (MWe /MWth)	460/1380	784/2381	784/2381	784/2381
Type of Reactor	BWR-3	BWR-4	BWR-4	BWR-4
Status at time of EQ	In service – auto shutdown	In service – auto shutdown	In service – auto shutdown	Outage
Core and fuel integrity	Damaged	Severe damage	Damaged	No fuel in the Reactor
RPV & RCS integrity	RPV temperature high but stable	RPV temperature stable	RPV temperature stable	Not applicable due to
Containment integrity	No information	Damage suspected	Damage suspected	outage plant status
AC Power	AC power available - power to instrumentation – Lighting to Central Control Room	AC power available – power to instrumentation – Lighting to Central Control Room	AC power available – power to instrumentation – Lighting to Central Control Room	AC power available – power to instrumentation – Lighting to Central Control Room
Building	Severe damage	Slight damage	Severe damage	Severe damage
Water level of RPV	Around half of Fuel is uncovered	Around half of Fuel is uncovered	Around half of Fuel is uncovered	
Pressure of RPV	Increasing	Stable	Stable	
CV Pressure Drywell	Increasing	Stable	Stable	Not applicable due to outage plant status
Water injection to RPV	Injection of freshwater – via mobile electric pump with off-site power	Injection of freshwater – via mobile electric pump with off-site power	Injection of freshwater – via mobile electric pump with off-site power	
Water injection to CV	No information	No information	No information	
Spent Fuel Pool Status 04/11/2011 06:00 UTC	Fresh water spraying completed by concrete pump truck	Freshwater injection to the Fuel Pool Cooling Line	Freshwater injection via Fuel Pool Cooling Line and Periodic spraying	Fresh water injected by concrete pump truck

Unit	5	6	
Power	784/2381	1100/3293	
Type of Reactor	BWR-4	BWR-5	International Atomic Energy Agency
Status at the EQ occurred	Outage	Outage	
Core and Fuel			Severe condition
RPV & RCS integrity			
Containment int.			Concern
AC Power	Cold Shutdown Being maintained using off- site electrical power and		No immediate concern
Building		Cold Shutdown Being maintained using off- site electrical power and	
Water level of RPV			
Pressure of RPV	existing plant equipment.	existing plant equipment.	
Containment Pressure			
Water injection to RPV			
Water injection to CV			
Spent Fuel Pool Status			

Information on Status of Nuclear Power Plants in Fukushima

Japan Atomic Industrial Forum, Inc.

Policy on information and compilation

JAIF will do its best to keep tracks on the information on the nuclear power plants quickly and accurately.

This JAIF-compiled information chart represents the situation, phenomena, and operations in which JAIF estimates and guesses the reactors and related facilities are, based on the latest data and information directly and indirectly made available by the relevant organizations when JAIF's updating works done. Consequently, JAIF may make necessary changes to descriptions in the chart, once (1) new developments have occurred in the status of reactors and facilities and (2) JAIF has judged so needed after reexamining the prior information and judgments.

Status of nuclear power plants in Fukushima as of <u>10:00, April 12th</u> (Estimated by JAIF)

Power Station	Fukushima Dai-ichi Nuclear Power Station			
Unit	1	2	3	4
Electric / Thermal Power output (MW)	460 / 1380	784 / 2381	784 / 2381	784 / 2381
Type of Reactor	BWR-3	BWR-4	BWR-4	BWR-4
Operation Status at the earthquake occurred	In Service -> Shutdown	In Service -> Shutdown	In Service -> Shutdown	Outage
Fuel assemblies loaded in Core	400	548	548	No fuel rods
Core and Fuel Integrity (Loaded fuel assemblies)	Damaged (70%*)	Damaged (30%*)	Damaged (25%*)	No fuel rods
Reactor Pressure Vessel structural integrity	Unknown	Unknown	Unknown	Not Damaged
Containment Vessel structural integrity	Not Damaged (estimation)	Damage and Leakage Suspected	Not damaged (estimation)	Not Damaged
Core cooling requiring AC power 1 (Large volumetric freshwater injection)	Not Functional	Not Functional	Not Functional	Not necessary
Core cooling requiring AC power 2 (Cooling through Heat Exchangers)	Not Functional	Not Functional	Not Functional	Not necessary
Building Integrity	Severely Damaged (Hydrogen Explosion)	Slightly Damaged	Severely Damaged (Hydrogen Explosion)	Severely Damaged (Hydrogen Explosion)
Water Level of the Rector Pressure Vessel	Fuel exposed partially or fully	Fuel exposed partially or fully	Fuel exposed partially or fully	Safe
Pressure / Temperature of the Reactor Pressure Vessel	Gradually increasing / Decreased a little after increasing over 400°C on Mar. 24th	Unknown / Stable	Unknown	Safe
Containment Vessel Pressure	Decreased a little after increasing up to 0.4Mpa on Mar. 24th	Stable	Stable	Safe
Water injection to core (Accident Management)	Continuing (Switch from seawater to freshwater)	Continuing (Switch from seawater to freshwater)	Continuing(Switch from seawater to freshwater)	Not necessary
Water injection to Containment Vessel (AM)	(To be confirmed)	to be decided (Seawater)	(To be confirmed)	Not necessary
Containment Venting (AM)	Temporally stopped	Temporally stopped	Temporally stopped	Not necessary
Fuel assemblies stored in Spent Fuel Pool	292	587	514	1331
Fuel Integrity in the spent fuel pool	Unknown	Unknown	Damage Suspected	Possibly damaged
Cooling of the spent fuel pool	Water spray started (ffreshwater)	Continued water injection (Switch from seawater to freshwater)	Continued water spray and injection (Switch from seawater to freshwater)	Continued water spray and injection (Switch from seawater to freshwater) Hydrogen from the pool exploded on Mar. 15th
Main Control Room Habitability & Operability	Poor due to loss of AC power Poor due to loss of AC power (Lighting working in the control room at Unit 1 and 2.) (Lighting working in the control room at Unit 3 and 4.)			
Environmental effect	Status in Fukushima Dar-ichi NPS site Radiation level: 0.58mSv/h at the south side of the office building, 78 μ Sv/h at the Main gate, 33 μ Sv/h at the West gate, as of 21:00. Apr. 11th Plutonium was detected from the soil sampled at Fukushima Dai-ichi NPS site on Mar. 21st, 22nd, 25th and 28th. The amount is so small that the Pu is not harmful to huma Radioactive materials were detected from underground water sampled near the turbine buildings on Mar. 30th. Radioactive materials exceeding the regulatory limit have been detected from seawater sample collected in the sea surrounding the Fukushima Dai-ichi NPS since Mar. 21st radioactive iodine, I-131, was detected from the seawater, which had been sampled near the water intake of Unit 2 on Apr. 2nd. It was found on Apr. 2nd that there was hig concrete pit housing electrical cables and this water was leaking into the sea through cracks on the concrete wall. It was confirmed on Apr. 6th that the leakage of water sid drilled around the pit. Release of some 10,000 tons of low level radioactive wastee into the sea began on Apr. 4th, in order to make room for the highly radioactive wate TEPCO and MEXT has expanded the monitoring for the surrounding sea area since Apr. 4th. Influence to the people's life Radioactive iodine, exceeding the provisional legal limit, was detected from tay was detected from tay and exit of the waste detected from Mar. 21st to 27th. Small fish caught in waters off the coast of libaraki on Apr. 4 have been found to contain radioactive cesium above the legal limit on Apr. 5th. It was decided on Apr. 5th tha amount for vegetbles should be applied to fibarery products for the time being.			
Evacuation	<3> Shall be evacuated for within 20km from NPS (issued at 18:25, Mar. 12th) <4> Shall stay indoors (issued at 11:00, Mar. 15th), Should consider leaving (issued at 11:30, N 20km evacuation zone around the Fukushima Daiichi NPS is to be expanded so as to include the area, where annual radiationo exposure is expected to be above 20mSv. For within a month or so. People living in the 20 to 30km and other than the expanded evacuation area mentioned above, are asked to get prepared for going and staying indoor 11th).			
INES (estimated by NISA)	Level 5	Level 5	Level 5	Level 3
Remarks	 Progress of the work to recover injection function Water injection to the reactor pressure vessel by temporally installed pumps were switched from seawater to freshwater at Unit 1, 2 and 3. High radiation circumstance hampering the work to restore originally installed pumps for injection. Discharging radioactive water in the basement of the buildings of Unit 1the transfer work is being made to secure a place the water to go. Lighting in the turbine buildings became partly available at Unit 1through 4. Function of containing radioactive material It is presumed that radioactive material inside the reactor vessel may leaked outside at Unit 1, 2 and Unit 3, based on radioactive material found outside. NISA announced the have lost air tightness because of low pressure inside the pressure vessel. NISA told that it is unlikely that these are cracks or holes in the reactor pressure vessels at the TEPCO started to inject nitrogen gas into the Unit 1 containment vessel to reduce the possibility of hydrogen explosion on Apr. 6th. The same measure will be taken for Un Cooling the spent fuel pool Steam like substance rose intermittently from the reactor building at Unit 1, 2, 3 and 4 has been observed. Injecting and/or spraying water to the spent fuel pool has been compared to the spent fuel pool has been compared. 			
[Source]	Prevention of the proliferation of contamin	[Abbreviations]	*TEPCO's	estimation based on the radiation level in the C

[Source] Government Nuclear Emergency Response Headquarters: News Release (-4/11 10:30), Press conference NISA: Nuclear and Industrial Safety Agency NISA: News Release (-4/11 15:00), Press conference TEPCO: Tokyo Electric Power Company, Inc. NSC: Nuclear Safety Commission of Japan NISA: News Release ($-4/11\ 15:00$), Press conference TEPCO: Press Release ($-4/11\ 21:00$), Press Conference

MEXT: Minstry of Education, Culture, Sports, Science and Technology

5	6	
784 / 2381	1100 / 3293	
BWR-4	BWR-5	
Outage	Outage	
548	764	
Not Dar	naged	
Not Dar	naged	
Funct	ional	
Function (in cold sl	oning nutdown)	
Dpen a vent hole on the roo explo	ftop for avoiding hydrogen sion	
Saf	fe	
Sat	fe	
Sat	Fe	
Not nec	essary	
Not nec	essary	
Not nec	essary	
946	876	
Not Dar	maged	
Pool cooling capabil	lity was recovered	
Not damaged (estimate)		
e the building on Mar. 27th. t. On Apr. 5th, 7.5 million ti hly radioactive (more than 1 opped after injecting a hard or mentioned above. Regard eral pubic receive from the nd intake (23rd-) for some t as a legal limit of radioact S (Issued at 05:44, Mar. 12th Mar. 25th) for from 20km to cople in the expanded zone s or evacuation in an emerge	imes the legal limit of 1000mSv/hr) water in the dening agent into holes ding the influence of the environment for a year. products. ive iodine, the same (n) 30km from NPS <5>The are ordered to evacuate gency (issued on Apr.	
—	—	
ough 3 continue to improve at the reactor pressure ves same occasion. t 2 and 3. onducted.	this situation. Water	
′ [Significance jud ■ Low High ■ Severe (Need	ged by JAIF] d immediate action)	

Power Station	Fukushima Dai-ni Nuclear Power Station			
Unit	1	2	3	4
Electric / Thermal Power output (MW)			00 / 3293	•
Type of Reactor	BWR-5	BWR-5	BWR-5	BWR-5
Operation Status at the earthquake occurred		In Service ->	Automatic Shutdown	
Status	All the units are in cold shutdown.			
INES (estimated by NISA)	Level 3	Level 3	<u> </u>	Level 3
Remarks	Unit-1, 2, 3 & 4, which were in full operation External power supply was available after the cooling function and made the unit into cold No parameter has shown abnormality after th Latest Monitor Indication: 2.7μ Sv/h at 21:00 Evacuation Area: 10km from NPS	when the earthquake occurred, all shi e quake. While injecting water into the shutdown state one by one. ne earthquake occurred off an shore o <u>), Apr. 11th</u> at NPS border	utdown automatically. e reactor pressure vessel using make-up v of Miyagi prefecture at 23:32, Apr. 7th.	water system, TEPCO recovered the core

Power Station	Onagawa Nuclear Power Station			
Unit	1 2 3			
Operation Status at the earthquake occurred	In Service -> Automatic Shutdown			
Status	All the units are in cold shutdown.			
Remarks	3 out of 4 external power lines in service with another line under construction broke down after an earthquake occurred off the shore of Miyagi prefecture at 23:32, Apr. 7th. All 5 external power lines have become available by Apr. 10th. Monitoring posts' readings have shown no abnormality. All SFP cooling systems had been restored after shutting down due to the earthquake.			

Power Station	Tokai Dai-ni		
Operation Status at the earthquake occurred	In Service -> Automatic Shutdown		
Status	In cold shutdown.		
Remarks	No abnormality has been found after an earthquake occurred off the shore of Miyagi prefecture at 23:32, Apr. 7th.		

Parameters in the Table

JAIF picks up these parameters to evaluate safety condition of the nuclear plants during this accident from the view point of the principles of nuclear power plant safety, which are "Shutdown", "Cooling" and "Containment". Then we create the chart. The following diagram is to show the correspondence relation of these parameters in the table to nuclear power plant safety.

.

Nuclear Power Plant Safety and	related items		Parameters in the tabl
Reactor Shutdown			→ Operation Status at the earthquake
	Design base cooling		Core cooling requiring AC power1 (Large volumetric freshwater injection)
	capability		Core cooling requiring AC power2 (Cooling through Heat Exchangers)
Containment		Design base 5 Barriers containment	
		Cladding Tube	Core and Fuel Integrity
		3 Reactor Pressure vessel	Reactor Pressure Vessel Integrity
			Containment Vessel pressure
		@Containment Vessel —	Containment Vessel Integrity
		5 Reactor Building	Building Integrity
<accident :="" am="" management=""></accident>	A		Injection to core (AM)
(Operation beyond design base accident)	operation	Operation for containment vessel	Injection to Containment Vessel (AM)
		protection against burst	Containment Venting (AM)
Safety of the spent fuel pool		Г	Fuel Integrity in the spent fuel pool (Fuel Damage)
			Cooling of the spent fuel pool (Water injection, pool temp, water level)
Work environment in main control roo	<u>m</u>		Main Control Room Habitability and Oper (ventiration, Lights, Indicator)
Environmental effect			Environmental effect (Radiatiom Monito
Evacuation			Evacuation (Order, Evacuated Area,)

1. Latest Major event and response

April 9th:

03:29 Nitrogen injection valve was closed in order to switch to the high purity nitrogen gas generator. (04:10 The valve was reopened.) 13:10 Transfer of water from the main condenser to the CST was completed at Unit 2.

April 10th:

09:30 Transfer of water from the main condenser to the CST was completed at Unit 1.

2. Chronology of Nuclear Power Stations

(1) Fukushima Dai-ichi NPS

	Unit 1	Unit 2	Unit 3	Unit 4
Major Incidents and Actions	11th 15:42 Report IAW Article 10* (Loss of power)	11th 15:42 Report IAW Article 10* (Loss of power)	11th 15:42 Report IAW Article 10* (Loss of power)	14th 04:08 Water temperature in Spent Fue Storage Pool increased at 84°C
The Act on Special Measures Concerning	11th 16:36 Event falling under Article 15 occurred (Incapability of water injection by core cooling function)	11th 16:36 Event falling under Article 15* occurred (Incapability of water injection by core cooling function)	12th 20:41 Start venting	15th 09:38 Fire occurred on 3rd floor (extinguished spontaneously)
Preparedness	12th 00:49 Event falling under Article 15* occurred (Abnormal rise of CV pressure)	13th 11:00 Start venting	13th 05:10 Event falling under Article 15* occurred (Loss of reactor cooling functions)	16th 05:45 Fire occurred (extinguished spontaneously)
	12th 14:30 Start venting	14th 13:25 Event falling under Article 15* occurred (Loss of reactor cooling functions)	13th 08:41 Start venting	Since 20th, operation of spraying water to t spent fuel pool continues.
	12th 15:36 Hydrogen explosion	14th 16:34 Seawater injection to RPV	13th 13:12 Seawater injection to RPV	29th 11:50 lights in the main control room becomes available
	12th 20:20 Seawater injection to RPV	14th 22:50 Report IAW Article 15* (Abnormal rise of CV pressure)	14th 05:20 Start venting	
	22nd 11:20 RPV temperature increased	15th 00:02 Start venting	occurred (Abnormal rise of CV pressure)	
	22nd 02:33 Seawater injection through feed water line started in addition to fire extinguish line	15th 06:10 Sound of explosion, Suppression Pool damage suspected	14th 11:01 Hydrogen explosion	
	24th 11:30 lights in the main control room becomes available	15th 08:25 White smoke reeked	15th 10:22 Radiation dose 400mSv/h	
	25th 15:37 Freshwater injection to the reactor started.	Since 20th, operation of spraying water to the spent fuel pool continues.	16th 08:34, 10:00 White smoke reeked	
	27th 08:30 Continuing to transfer the water in the basement of the turbine building	21st 18:22 White, steam-like smoke erupted from the top of the rector building.	Since 17th, operation of spraying water to the spent fuel pool continues.	
	31st 09:20-11:25 Work to remove the water in the trench	26th 10:10 Freshwater injection to the reactor started.	21st 15:55 Slightly gray smoke erupted (18:02 settled)	
	31st 12:00 Start to transfer the water in the CST to the surge tank (- 15:27, Apr. 2)	26th 16:46 lights in the main control room becomes available	22nd 22:46 lights in the main control room becomes available	
	31st 13:03 Start water injection to SFP	29th 16:45 Start to transfer the water in the CST to the surge tank	25th 18:02 Freshwater injection to the reactor started.	
	Apr. 7th 01:31 Injection of Nitrogen gas started after opening all valves through the line.	Apr. 2nd 16:25 Start injecting concrete to stop water leakage from the pit near the intake	28th 17:40 Start to transfer the water in the CST to the surge tank	
	Apr. 10th 09:30 Transfer of water from the main condenser to the CST completed.	2nd 17:10 Start transferring water in the condenser to the CST		
		Apr. 5th 15:07 Regarding leakage from the pit that is closed to discharge outlet of unit-2, hardening agent was injected to hole dug surrounding the pit (Apr. 6		
		05:38 It was confirmed that the highly radioactive water flow mentioned above stopped.)		
		Apr. 9th 13:10 Transfer of water from the main condenser to the CST completed.		
	Apr. 3rd 12:18 Switch power supply for water injection	ction pumps to the RPV from power supply vehicles to or	iginally equipped power source	
Major Data	Reactor Water level (<u>Apr. 11 12:00</u>) (A) <u>-1600mm</u> (B) <u>-1650mm</u>	Reactor Water level (Apr. 11 06:00) -1500mm	Reactor Water level (Apr. 11 06:00) (A) -1900mm, (B) -2250mm	Thermography (Apr. 08 07:30) SFP: 46°C
	Reactor pressure (Apr. 11 06:00) (A) 0.410MPaG, (B) 0.873MPaG	Reactor pressure (Apr. 11 06:00) (A) -0.025MPaG, (B) -0.029MPaG	Reactor pressure (Apr. 11 06:00) (A) -0.015MPaG, (B) -0.081MPaG	
	CV pressure (Apr. 11 06:00) 0.195MPaabs	CV pressure (Apr. 11 06:00) 0.090MPaabs	CV pressure (Apr. 11 06:00) 0.1031MPaabs	
	RPV temperature (Apr. 11 06:00) 222.9°C at feed water line nozzle	RPV temperature (Apr. 11 06:00) 153.6°C at feed water line nozzle	RPV temperature (Apr. 11 06:00) 97.7°C at feed water line nozzle	
	(to be confirmed)	71.0°C	(to be confirmed)	
	CV: 33°C, SFP: 23°C	Top of R/B: 30°C	CV: 35°C, SFP: 56°C	
2) Fukushima Dai-ni NPPs				*SFP: Spent Fuel Storage Pool

All units are cold shutdown (Unit-1, 2, 4 have been recovered from a event falling under Article 15*)

3. State of Emergency Declaration

11th 19:03 State of nuclear emergency was declared (Fukushima Dai-ni NPS)

12th 07:45 State of nuclear emergency was declared (Fukushima Dai-ichi NPS)

4. Evacuation Order

11th 21:23 PM direction: for the residents within 3km radius from Fukushima I to evacuate, within 10km radius from Fukushima I to stav in-house 12th 05:44 PM direction: for the residents within 10km radius from Fukushima I to evacuate

12th 17:39 PM direction: for the residents within 10km radius from Fukushima II to evacuate

12th 18:25 PM direction: for the residents within 20km radius from Fukushima I to evacuate

15th 11:06 PM direction: for the residents within 20-30km radius from Fukushima I to stay in-house

25th Governmental advise: for the residents within 20-30 km radius from Fukushima I to voluntarily evacuate

EDG: Emergency Diesel Generator RPV: Reactor Pressure Vessel R/B: Reactor Building RHR: Residual Heat Removal system CST: Condensate water Storage Tank

	Unit-5 and 6
	19th 05:00 Cooling SFP with RHR-pump started at Unit 5
	10th 22:14 Cooling SED with PUP nump started at Unit 6
	20th 14:30 Cold shutdown achieved at Unit 5.
	20th 19:27 Cold shutdown achieved at Unit 6
	22nd 19:41 All power source was switched to external AC
	power at Unit 5 and 6.
Э	
-	Apr. 1st 13:40 Start transferring pooled water in the Unit 6
	radioactivo wooto processo facility to the Unit E condense
	radioactive waste process facility to the Unit 5 condenser.
	Water temperature of SEP
	$\frac{1}{100} = \frac{361^{\circ} C}{100} (\text{Apr} \ 11 \ 07.00)$
	Unit 6 23.0°C (Apr. 11 07:00)

Status of the Nuclear Power Plants after the Earthquake

Tomari

The accident that brings environmental impact is going on at several units in Fukushima Daiichi nuclear power Station after the earthquake occured on March 11th. Other nuclear power plants in Japan are in normal operation or safely shutdown.

THE WALL STREET JOURNAL | ASIA

MAY 13, 2011

At Reactor, Damage Worse Than Feared

Unit at Japan's Fukushima Nuclear Plant Came Closer to Meltdown Than Previously Revealed; Questions Over Quake's Role

By <u>MITSURU OBE</u> and <u>PHRED DVORAK</u> in Tokyo and <u>REBECCA SMITH</u> in San Francisco

One of the reactors at Japan's Fukushima Daiichi nuclear plant likely suffered a substantial meltdown of its core, operator <u>Tokoyo Eectric Power</u> Co. said Thursday, offering a fresh assessment of the reactor that suggests it came closer than the operator had previously revealed to a catastrophic meltdown.

Japan agrees to bail out Tepco as news develops that a nuclear reactor suffered a partial meltdown in the Fukushima plant. And in the latest effort to rein in inflation, China orders banks to raise reserve ratios. WSJ's Jake Lee and Peter Stein discuss.

It is likely that the fuel rods that form the core of Reactor No. 1 had more than half melted in March, Tepco spokesman Junichi Matsumoto said Thursday. That assessment came after Tepco this week determined that both of the vessels that surround the reactor core may be damaged, leaking water that is supposed to be keeping the core cool.

The reactor core is still contained inside those vessels, Mr. Matsumoto said, and the temperature is stable. That indicates the accident didn't reach the most severe level, where fuel rods melt through those vessels and release massive amounts of radioactive material to the outside.

The findings raise a host of questions about the chain of events that led to the damage and have implications for future plant regulation in Japan and beyond. It also suggests that radioactive water has leaked into the reactor's basement in greater-than-believed quantities, likely dealing additional delays to the stricken plant's cleanup.

Tepco's assessment came after workers entered the reactor building this week and fixed a faulty waterlevel gauge. They determined that the reactor's pressure vessel—the cylindrical steel container that houses the fuel rods—had only about half the level of cooling water as previously thought.

That suggested Reactor No. 1 is likely more severely damaged than Tepco believed and could be leaking large amounts of highly radioactive water. It also shows that the area enclosing the fuel rods wasn't mostly submerged in cooling water, as Tepco had thought, but was instead high and dry.

The finding spurred experts to ask whether leaks or holes could have been caused by the 9-magnitude earthquake that struck Japan's northeastern coast on March 11. Tepco has said the damage at Fukushima Daiichi resulted from the subsequent tsunami, which cut power to the plant's cooling systems, causing reactor temperatures and pressure to rise to damaging levels.

If it turns out that Reactor No. 1's vessels were in fact damaged by the quake, that would lead to a

wholesale review of earthquake standards for nuclear plants, warned Ken Nakajima, a professor of nuclear engineering at the Research Reactor Institute, Kyoto University.

Earthquake in Japan

In the U.S., 23 reactors have designs similar to the reactors at the Fukushima Daiichi site. Findings about possible damage caused by the earthquake, independent of the tsunami, will be incorporated into an analysis of seismic hazards in the eastern and central U.S. being conducted by NRC, said Scott Burnell, spokesman for the U.S. Nuclear Regulatory Commission.

Some U.S. experts said Tepco simply has acknowledged what U.S. nuclear experts already believed was the case—that severe core damage has occurred which allowed radioactive material to migrate outside the thick steel walls of the pressure vessel. One indication of this breakdown in normal protective barriers has been the high radiation readings in the containment area and reactor building.

Previously, Tepco officials had said they believed there had been "damage" to the fuel rods but didn't specify what that meant. On Thursday, for the first time, officials conceded that the fuel rods likely had "melted," crumbled or changed shape, and that the fuel had probably fallen from its casings.

The nuclear industry lacks a technical definition for a full meltdown, but the term is generally understood to mean that radioactive fuel has breached containment measures, resulting in a massive release of fuel.

Tepco engineers estimate that 90% of the fuel is still in the inner pressure vessel and that there are no cracks or obvious ruptures to the outer containment vessel, where Mr. Matsumoto said the rest of the fuel is likely contained. So the risk of a large radioactive release of fuel is minimal, he said.

In response to a question about whether the situation could be described as a "meltdown," Mr. Matsumoto said that if the definition is that the fuel rods melt and lose their shape, "that is fine."

Soon after the March 11 quake and tsunami knocked out the plant's cooling systems, temperatures in the No. 1 reactor likely rose to more than 2,000 degrees Celsius, experts have said, well above the point at which the metal casings of the fuel rods would begin to melt. The fuel pellets inside would start melting at 2,800 degrees, potentially fusing into a dangerous large mass. Tepco estimates the fuel rods in the No. 1 reactor have been 55% destroyed, making it the worst-damaged of the plant's six reactors.

The temperature in the pressure vessel now hovers around 100 to 120 degrees Celsius, indicating progress in the cooling effort, Mr. Matsumoto said.

The tops of the four-meter-long fuel rods reach a little more than nine meters from the bottom of the pressure vessel; past data suggested the water was eight meters deep, enough to mostly submerge them. When workers entered the reactor building this week and corrected the water gauge, it told them the depth was just four meters.

If the rods were intact, that would leave them dry. But Mr. Matsumoto said he believes that some of the fuel slid down and is likely sitting in water.

A top U.S. Nuclear Regulatory Commission official expressed concern Thursday with potential structural problems at a stricken Japanese nuclear plant. "The reliability of instrumentation complicates our understanding of the exact plant conditions at any given time," said Bill Borchardt, the commission's executive director of operations.

Thursday's news signals likely delays as Tepco figures out how to deal with possible leaks. Tepco has injected 10.4 million liters of cooling water into the Reactor No. 1 vessel so far, much of which the

company says it now suspects has been leaking from the pressure vessel and the larger beaker-shaped containment vessel that surrounds it.

That water is likely accumulating in the basement of the reactor building, where radiation levels are still too high for anyone to enter.

If so, Tepco would need another huge operation to collect and decontaminate the water, similar to one already conducted at Reactor No. 2.

"The biggest challenge for us is how to repair damaged parts of the containment vessel," Mr. Matsumoto said.

Tepco and regulators have a six-to-nine-month road map to bring all the reactors to a state of cold shutdown and end the continued release of radiation that has forced mass evacuations from the area.

Since May 6, the company has tried to flood the No. 1 containment vessel with enough water to submerge the pressure vessel and bring the temperature of the fuel inside to a safe temperature. Tepco will have to revise its plans to fill the reactor unit with water, since that requires the containment vessel be whole.

Workers would have to fix any leaks in the containment vessel before the pressure vessel could be submerged, Mr. Matsumoto said. That presents problems too, since the area around the containment vessel is highly radioactive, meaning that workers can't be there for long.

—Ryan Tracy in Washington contributed to this article.